

2019 07 13  
2019 07 13

|               |    |      |   | 2019 7 13 |         |      |      |      |        |        |       |       |
|---------------|----|------|---|-----------|---------|------|------|------|--------|--------|-------|-------|
|               | 1  | 2    | 3 | 4         | 5       | 6    | 7    | 8    | 9      | 10     | 11    | 12    |
|               |    |      |   |           | pH      |      |      |      |        |        |       |       |
|               |    | NTU  |   |           |         | /L   | /L   | CF / | M /100 | M /100 | /L    | /L    |
| 1907131( )    | 25 | 2.23 |   |           | 7.76    | 1.36 | /    | /    | /      | /      | 0.378 | 0.107 |
| 1907132( )    | 5  | 0.15 |   |           | 7.66    | 0.64 | 0.16 | /    | /      | /      | <0.02 | <0.01 |
|               |    |      |   |           |         |      |      |      |        |        |       |       |
| GB3838-2002   |    |      |   |           |         | 6    |      |      |        | 10000  |       |       |
| GB/T5849-2006 | 15 | 1    |   |           | 6.5-8.5 | 3    | 0.1  | 100  |        |        | 0.3   | 0.1   |