

2023 07 01

2023 07 01

				2023 7 01												
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
	mg/L	mg/L		NTU			pH	mg/L	CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L	mg/L	mg/L
2307011( )	-	-	25	30.2	0		7.30	2.80	/	/	/	-	-	0.214	0.177	0.032
2307012( )	0.29	0.44	<5	0.136	0		7.23	1.36	/	/	-	/	0.02	<0.02	<0.02	0.011
GB3838-2002							6.9	6			10000			1.0	0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2	15	1			6.5 8.5	3	100				0.5		0.3	0.1
	(GB5750-2006)					1 2										