

2023 06 02

2023 06 02

				2023 6 02												
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
				NTU			pH		CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L	mg/L	mg/L
2306021( )	-	-	15	1.780	0		7.20	2.64	/	/	/	-	-	0.207	0.142	0.172
2306022( )	0.21	0.27	5	0.215	0		7.30	1.44	/	/	-	/	0.02	-	<0.02	0.027
GB3838-2002							6.9	6			10000			1.0	0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2		1			6.5 8.5	3	100				0.5		0.3	0.1
	(GB5750-2006)					1 2										