

2023 09 19

2023 09 19

				2023 9 19												
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
				NTU			pH		mg/L	mg/L	CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L
230919YS01	-	-	25	35.2			8.38	4.88	-	0.566	/	/	/	/	0.10	0.03
230919C001	0.22	0.31	<5	0.16			7.36	1.68	0.07	-	/	/	/	/	0.10	0.03
GB3838-2002							6.9	6		1.0			10000		0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2		1			6.5 8.5	3	0.5		100				0.3	0.1
	(GB5750-2023)					1. 2.										