

2023 09 24

2023 09 24

				2023 9 24												
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
				NTU			pH		mg/L	mg/L	CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L
2309241()	-	-	30	23.8	0		7.32	3.60	-	0.183	/	/	/	-	0.047	0.01
2309242()	0.25	0.34	5	0.082	0		7.22	1.52	0.02	-	/	/	-	/	0.02	0.01
GB3838-2002							6.9	6		1.0			10000		0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2		1			6.5 8.5	3	0.5		100				0.3	0.1
	(GB5750-2006)					1										
						2										