

2023 09 01

2023 09 01

				2023 9 01												
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
				NTU			pH		CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L	mg/L	mg/L
2309011( )	-	-	20	10.3	0		7.36	2.96	/	/	/	-	-	0.247	0.062	0.016
2309012( )	0.13	0.17	<5	0.158	0		7.42	1.20	/	/	-	/	0.02	<0.02	<0.02	0.01
GB3838-2002							6.9	6			10000			1.0	0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2		1			6.5 8.5	3	100				0.5		0.3	0.1
	(GB5750-2006)					1 2										